



Ref. Certif. No.
SE-101946

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Connector
Name and address of the applicant	NEUTRIK AG Im alten Riet 143, 9494 Schaan, Liechtenstein
Name and address of the manufacturer	Same as applicant
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Same as applicant
Ratings and principal characteristics	250V AC, 20A, IP20
Trademark (if any)	NEUTRIK or 
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	NAC3MPA-1, NAC3MPB-1, NAC3MPA-1-WOT NAC3MPB-1-WOT, NAC3FCA-1, NAC3FCA-1-JAPAN NAC3FCB-1, NAC3FCB-1-JAPAN
Additional information (if necessary may also be reported on page 2)	See page 2
A sample of the product was tested and found to be in conformity with	IEC 61984:2008
As shown in the Test Report Ref. No. which forms part of this Certificate	2019103STO-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

Date: 18 August, 2020

intertek

Signature:


Henrik Wikström

Additional information

Cable and fixed connectors for power applications.

COC without interlock.

Fixed connectors with tab terminals (4,8 x 0,5mm).

Cable connectors with screw terminals. PTI: 175. Pollution degree 2, overvoltage category II, number of conductors 3, conductor area 1,5 – 4,0 mm².

Additional flammability information:

Type	Part	Material	Thickness	Flammability
Fixed connectors NAC3*	Inserts (blue or grey)	PA66	0,4 – 2,0 mm	V-0 UL 94
Fixed connectors NAC3*	Cover/Housing (black)	PA66	0,4 – 2,0 mm	V-0 UL 94
Free connectors NAC3*	Insert (black)	PA66	0,4 – 2,0 mm	V-0 UL 94
Free connectors NAC3*	Housing (blue or grey)	PA6	0,5 – 2,0 mm	HB UL 94

Date: 18 August, 2020

Signature: 